

Children First

Inspection date: _____

This inspection reflects the homes condition at time of the inspection.

Inspector Print Name _____ Sign _____

Provider Print Name _____ Sign _____

Address of Inspection _____ Phone: _____ County _____

Satisfactory		Fire Inspection	
Yes	No		
		Home Exterior	
		House address (numbers) easily seen from street	
		Dry grass, weeds and debris not accumulating	
		Caution is used when operating barbeque grill	
		Swimming pool Notes:	
		County regulations followed	
		<input type="checkbox"/> Above ground <input type="checkbox"/> Underground <input type="checkbox"/> Wading	
		Wading pools are emptied after every use	
		Empty buckets are tipped up side down	
		Home Interior	
		Exits easily recognized and not blocked	
		At least 1 Smoke detector installed in sleeping areas <i>Notes:</i>	
		At least 1 smoke detector on each level	
		Emergency numbers posted <i>Can use blue building for future for both emergency numbers and escape plan.</i>	
		Escape plan posted (<i>see above</i>)	
		Outlets are covered in play area's	
		Grease on hood and fan motor removed	
		Practice fire drills at least once every 6 months (<i>monthly is best</i>)	
		No electrical cords/ extension cords under rugs, traffic areas, over nails or going from room to room	
		No extension cords on permanent basis must be UL or FM approved	
		Candles, matches and lighters and other flammable objects are out of children's reach.	
		Fire place with screen (metal mesh no longer than 1/2 inch. opening)	
		Other:	
		Supplies	
		Fire extinguisher size: How many in house hold: Recommendation for additional size if any:	
		First aid supplies on hand	
		Storage	
		Storage keep 24 inches from ceiling	
		Scuttle hole to attic closed at all times	
		Gasoline stored in proper container and away from heat producing appliances	
		Flammable/combustible materials stored away from heat producing or spark-producing appliances	
		Acid and chlorine stored away from each other and not near petroleum -based products such as oil, brake fluid etc...	
		Electric Panel All circuits labeled and blanks are in empty circuits	
		Completed First Available Schedule Date.	

This form is general guidelines for fire inspections.

This form must be completed by approved inspector.

Child Care provider must provide proof item/s are corrected if non-satisfactory. Proof must be provided to validate qualification status. Proof of supporting documents showing items are corrected include; receipt or even a photo showing the item was corrected, send supporting document/s to Children First (ASAP). Text 1-928-978-2151, Fax 1-928-468-8351, daycarechildrenfirst@hotmail.com

Note: _____